



MODEL	FILL	CAPACITY
700CB-2	2"MPT	16gal/16gal
700CB-3	3"MPT	16gal/16gal
700CB-4	4"MPT	16gal/16gal
750CB-2	2"FPT	16gal/16gal
750CB-3	3"FPT	16gal/16gal
750CB-4	4"FPT	16gal/16gal
770CB-2**	2"comp.boot	16gal/16gal
770CB-3**	3"comp.boot	16gal/16gal
770CB-4**	4"comp.boot	16gal/16gal

-S" following any model no. designates stainless steel construction.  
 \*\* Cutout and bolt holes pre-drilled for UL Listed environ flexible entry boot (supplied with unit).

- MATERIALS:**
- **SPILL CONTAINMENT CABINET:**  
16GA STEEL MINIMUM (ALT "S" 16GA MINIMUM STAINLESS STEEL)
  - **MOUNTING BRACKETS:**  
1/4" X 2" STEEL FLAT BAR (ALT "S" STAINLESS STEEL)
  - **FILL AND DRAIN PIPE FITTINGS:**  
ALL STEEL, SCH 40 MIN (ALT "S" S/S SCH 40 MIN)
  - **LOCK TABS:**  
3/16" STEEL WITH 1/2"DIA PADLOCK HOLE (ALT "S" 3/16" STAINLESS STEEL)
  - **COATING:**  
POWDERCOAT EPOXY FINISH INTERIOR AND EXTERIOR (ALT "S" BARE STAINLESS STEEL, NO COATING)

**CAUTION**  
 FLAMMABLE OR COMBUSTIBLE LIQUIDS/VAPORS MAY BE PRESENT. KEEP AWAY SPARKS, FLAME, IGNITION SOURCES. EXTINGUISH SMOKING MATERIALS. FOR USE WITH PROPERLY VENTED STORAGE VESSELS. KEEP DOOR CLOSED AND LOCKED WHEN NOT IN USE.

This drawing and design are proprietary to BAKER INDUSTRIES NORTHWEST, and may not be copied or duplicated in whole or in part without the written permission of BAKER INDUSTRIES NW.

#700 SERIES GROUND LEVEL SPILL CONTAINMENT  
 MULTIPLE COMPARTMENT MODELS WITH TANK MOUNTING BRACKETS



BAKER INDUSTRIES NORTHWEST  
 12428 Highway 99 South, Unit 56  
 Everett, Washington 98204-5502  
 Tel:(425)212-3169 • FAX:(425)353-6788 • e-mail: [larry@bakerindnw.com](mailto:larry@bakerindnw.com)  
[www.bakerindustriestnorthwest.com](http://www.bakerindustriestnorthwest.com)

REV	DRAWN	CHECKED	DATE
REV	LRG	RBW	03-28-95
REV	SLG	LRG	03-05-06
REV			