



MODEL	FILL	DEPTH*	CAPACITY
800-4-75P	4" MPT	10-1/2"	7-1/2 GAL
800-3-75P	3" MPT	10-1/2"	7-1/2 GAL
800-2-75P	2" MPT	10-1/2"	7-1/2 GAL
800-4-50P	4" MPT	7-1/2"	5 GAL
800-3-50P	3" MPT	7-1/2"	5 GAL
800-2-50P	2" MPT	7-1/2"	5 GAL

\*includes 1/2" dished bottom

**MATERIALS:**

- **PAN:**  
SEAMLESS FORMED 14GA CR STEEL
- **LID:**  
SEAMLESS 16GA CR STEEL (ALT 5052-H32 ALUMINUM)
- **HINGE ASSY:**  
CARBON STEEL 10GA  
PIN: 5/16" DIA ZINC PLATED  
NUT: 5/16"-18 NYLOC, ZINC PLATED
- **HANDLE:**  
1/8" X 1" FB STEEL (ALT 5052-H32 ALUMINUM)
- **LOCK TAB:**  
1/8" X 1" FLAT BAR STEEL
- **FILL/DRAIN FITTING:**  
SCH 40 STEEL (MIN)
- **DRAIN PLUG ASSY:**  
3/8" DIA STEEL ROUND BAR WELDED TO 1/2" MPT STEEL PIPE PLUG
- **COATING:**  
POWDERCOAT ZINC RICH EPOXY INT/EXT W/2<sup>ND</sup> COAT  
EXTERIOR POLYESTER

**CAUTION**

FLAMMABLE OR COMBUSTIBLE LIQUIDS/VAPORS MAY BE PRESENT. KEEP AWAY SPARKS, FLAME, IGNITION SOURCES. EXTINGUISH SMOKING MATERIALS. FOR USE ONLY ON PROPERLY VENTED ABOVEGROUND STORAGE TANKS. KEEP LID CLOSED AND OPENINGS SECURELY PLUGGED EXCEPT DURING ACTUAL TANK FILLING.

**HINGE ASSEMBLY DETAIL**  
Die stamped hinge assy. and positive "up stop" tabs

This drawing and design are proprietary to BAKER INDUSTRIES NORTHWEST, and may not be copied or duplicated in whole or in part without the written permission of BAKER INDUSTRIES NW.

**#800 SERIES TANK TOP SPILL CONTAINMENT FOR ABOVEGROUND TANKS**

BAKER INDUSTRIES NORTHWEST

12428 Highway 99 South, Unit 56  
Everett, Washington 98204-5502

Tel:(425)212-3169 • FAX:(425)353-6788 • e-mail: [larry@bakerindnw.com](mailto:larry@bakerindnw.com)  
[www.bakerindustriessouthwest.com](http://www.bakerindustriessouthwest.com)

REV	DESCRIPTION	DRAWN	CHECKED	DATE
REV		KF	LRG	10-03-92
REV		KF	LRG	01-07-93
REV		SLG	LRG	03-05-06

