



MODEL	FILL	Depth	CAPACITY
850-4-75P	4"FPT	10 1/2"	7 1/2 GALLON
850-3-75P	3"FPT	10 1/2"	7 1/2 GALLON
850-2-75P	2"FPT	10 1/2"	7 1/2 GALLON
850-4-50P	4"FPT	7 1/2"	5 GALLON
850-3-50P	3"FPT	7 1/2"	5 GALLON
850-2-50P	2"FPT	7 1/2"	5 GALLON

*Includes 1/2" dished bottom

MATERIALS:

- **PAN:**
SEAMLESS FORMED 14GA CR STEEL
- **LID:**
SEAMLESS 16GA CR STEEL (ALT 5052-H32 ALUMINUM)
- **HINGE ASSY:**
CARBON STEEL 10GA
PIN: 5/16"DEA ZINC PLATED
NUT: 5/16"-18 NYLOC, ZINC PLATED
- **HANDLE:**
1/8" X 1"FB STEEL (ALT 5052-H32 ALUMINUM)
- **LOCK TAB:**
1/8" X 1" FLAT BAR STEEL
- **FILL/DRAIN FITTING:**
SCH 40 STEEL (MIN)
- **DRAIN PLUG ASSY:**
3/8"DIA STEEL ROUND BAR WELDED TO 1/2"MPT STEEL PIPE PLUG
- **COATING:**
POWDERCOAT EPOXY FINISH INT/EXT

CAUTION

FLAMMABLE OR COMBUSTIBLE LIQUIDS/VAPORS MAY BE PRESENT. KEEP AWAY SPARKS, FLAME, IGNITION SOURCES. EXTINGUISH SMOKING MATERIALS. FOR USE ONLY ON PROPERLY VENTED ABOVEGROUND STORAGE TANKS. KEEP LID CLOSED AND OPENINGS SECURELY PLUGGED EXCEPT DURING ACTUAL TANK FILLING.

HINGE ASSEMBLY DETAIL
Die stamped hinge assy. and positive "up stop" tabs

This drawing and design are proprietary to BAKER INDUSTRIES NORTHWEST, and may not be copied or duplicated in whole or in part without the written permission of BAKER INDUSTRIES NW.

#800 SERIES TANK TOP SPILL CONTAINMENT FOR ABOVEGROUND TANKS

BAKER INDUSTRIES NORTHWEST

12428 Highway 99 South, Unit 56
Everett, Washington 98204-5502

Tel:(425)212-3169 • FAX:(425)353-6788 • e-mail: larry@bakerindnw.com
www.bakerindustriestnorthwest.com

REV

REV

REV

DRAWN

LRG

SLG

CHECKED

RBW

LRG

DATE

01-07-93

03-05-06

